

Government of Bihar
Public Health Engineering Department
Water Quality Test Report


District Name: Gopalganj

Division Name: P.H.Division Gopalganj


GPJ/26/27G1

GPJ/26/27G1

SL No.	Block	Panchayat	Village	Ward No.	Location of Source	Parameters												Date of Testing	Remarks	
						pH	Turbidity (NTU)	EC	TDS (mg/l)	Total Hardness (mg/l)	Calcium (mg/l)	Magnesium (mg/l)	Chloride (mg/l)	Total Alkalinity (mg/l)	Iron (mg/l)	Nitrate (mg/l)	Sulphate (mg/l)			Fluoride (mg/l)
1	Hathua	Kandhgopi	Bhairopatti	2	Genesis Public School	7.89	0.1	512	332	256	64	28	18	284	0.23	0.58	89.4	0.2	10/10/2026	
Desirable Limit*						6.5-8.5	1.0	-	500	200	75	30	250	200	0.3	45	200	1.0		
Permissible Limit* in absence of alternate source (IS 10500:2012 - 2nd revision & Rev 2015)						NR	5.0	-	2000	600	200	100	1000	600	1.0	NR	400	1.5		


 10/10/26
 Lab Assistant / Chemist
 DLL, P.H. Division, Gopalganj


 10/10/26
 P.H.Division, Gopalganj


 10/10/26
 Executive Engineer
 P.H.Division, Gopalganj


Principal
 Genesis Public School
 Bhairopatti, Line Bazar Road,
 Hathua, Gopalganj


Manager
 Genesis Public School
 Bhairopatti, Line Bazar Road,
 Hathua, Gopalganj